

# Certificate



**No.: 968/FSP 2081.00/20**

<b>Product tested</b>	COMBIVIS studio Programming System	<b>Certificate holder</b>	KEB Automation KG Südstraße 38 32683 Barntrup Germany
<b>Type designation</b>	COMBIVIS studio For version details please see Revision List.		
<b>Codes and standards</b>	IEC 61508 Parts 1-7:2010 (in extracts) EN ISO 13849-1:2015 (in extracts)	EN 62061:2005 + AC:2010 + A1:2013 + A2:2015 (in extracts)	
<b>Intended application</b>	COMBIVIS studio complies with requirements of a T3 tool according to IEC 61508 as well with the applicable requirements of EN ISO 13849-1 and EN 62061.  COMBIVIS studio is therefore suitable for use in applications up to PL e according to EN ISO 13849-1 and SIL 3 according to EN 62061 / IEC 61508.		
<b>Specific requirements</b>	The instructions of the associated operating manual shall be considered.  The latest versions of the software are specified in the Revision Release List, released by the manufacturer in cooperation with the Certification Body.		

Valid until 2025-07-01


The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 2081.00/20 dated 2020-07-01.

This certificate is valid only for products which are identical with the product tested.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2020-07-01

Certification Body Safety & Security for Automation & Grid

  
Dipl.-Ing. Gebhard Bouwer